

## CALALA WATER TREATMENT PLANT - YEARLY SUMMARY FOR 2013/14

LICENCE PERIOD: 27th Feb 2013 - 26th Feb 2014

POINT 1 NOTE: Monitoring Frequency - Monthly

Pollutant	Units	90th Percentile Concentration Limit	Monitoring Frequency	Number of Samples	Minimum Value	Maximum Value	Mean	Median	Exceedances (Yes / No)
pH	pH Units	6.5 - 8.5	Monthly	12	7.40	8.00	7.66	-	No
TSS	mg/L	50	Monthly	12	2.0	15.0	5.8	-	No
Aluminium	mg/L	-	Monthly	12	0.22	1.62	0.71	-	-