

## CALALA WATER TREATMENT PLANT - YEARLY SUMMARY FOR 2014/15

LICENCE PERIOD: 27th Feb 2014 - 26th Feb 2015

POINT 1 NOTE: Monitoring Frequency - Monthly

Pollutant	Units	90th Percentile Concentration Limit	Monitoring Frequency	Number of Samples	Minimum Value	Maximum Value	Mean	Median	Exceedances (Yes / No)
pH	pH Units	6.5 - 8.5	Monthly	12	7.40	8.10	7.72	7.70	No
TSS	mg/L	50	Monthly	12	2.0	15.0	5.7	4.5	No
Aluminium	mg/L	-	Monthly	12	0.22	1.62	0.73	0.62	-