

CALALA WATER TREATMENT PLANT - YEARLY SUMMARY FOR 2015/16

LICENCE PERIOD: 27th Feb 2015 - 26th Feb 2016

POINT 1 NOTE: Monitoring Frequency - Monthly

Pollutant	Units	90th Percentile Concentration Limit	Monitoring Frequency	Number of Samples	Minimum Value	Maximum Value	Mean	Median	Exceedances (Yes / No)
pH	pH Units	6.5 - 8.5	Monthly	12	7.50	8.20	7.98	8.05	No
TSS	mg/L	50	Monthly	12	3.0	9.0	4.5	4.0	No
Aluminium	mg/L	-	Monthly	12	0.34	1.49	0.66	0.55	-