

CALALA WATER TREATMENT PLANT - YEARLY SUMMARY FOR 2016/17

LICENCE PERIOD: 27th Feb 2016 - 26th Feb 2017

POINT 1 NOTE: Monitoring Frequency - Monthly

Pollutant	Units	90th Percentile Concentration Limit	Monitoring Frequency	Number of Samples	Minimum Value	Maximum Value	Mean	Median	Exceedances (Yes / No)
pH	pH Units	6.5 - 8.5	Monthly	12	7.00	8.10	7.72	7.90	No
TSS	mg/L	50	Monthly	12	2.0	11.0	4.9	4.0	No
Aluminium	mg/L	-	Monthly	12	0.20	2.65	0.66	0.42	-