

CALALA WATER TREATMENT PLANT - YEARLY SUMMARY FOR 2017/18

LICENCE PERIOD: 27th Feb 2017 - 26th Feb 2018

POINT 1 NOTE: Monitoring Frequency - Monthly

Pollutant	Units	90th Percentile Concentration Limit	Monitoring Frequency	Number of Samples	Minimum Value	Maximum Value	Mean	Median	Exceedances (Yes / No)
pH	pH Units	6.5 - 8.5	Monthly	12	7.30	8.00	7.72	7.75	No
TSS	mg/L	50	Monthly	12	3.0	10.0	5.4	4.5	No
Aluminium	mg/L	-	Monthly	12	0.32	1.04	0.70	0.75	-