

CALALA WATER TREATMENT PLANT - CURRENT YEAR

LICENCE PERIOD: 27th Feb 2018 - 26th Feb 2019

POINT 1 NOTE: Monitoring Frequency - Monthly

Sample Date	pH	TSS	Aluminium	Sign Off
EPA Limit	6.5 - 8.5	50	N/A	Initial
20/03/2018	8.0	6	0.82	AA
17/04/2018	7.9	6	0.92	AA
15/05/2018	7.9	4	0.72	AA
20/06/2018	8.0	5	1.07	AA
24/07/2018	7.9	9	2.44	AA
27/08/2018	8.2	<2	1.04	AA
18/09/2018	8.0	6	0.87	AA
16/10/2018	8.0	6	1.02	AA
20/11/2018	7.7	6	0.92	AA
18/12/2018	8.1	3	0.67	AA
15/01/2019	8.1	3	0.53	AA
20/02/2019	8.1	4	0.63	AA

