

# CALALA WATER TREATMENT PLANT - CURRENT YEAR

LICENCE PERIOD: 27th Feb 2019 - 26th Feb 2020

POINT 1 NOTE: Monitoring Frequency - Monthly

Sample Date	pH	TSS	Aluminium	Sign Off
EPA Limit	6.5 - 8.5	50	N/A	Initial
19/03/2019	8.0	3	0.56	AA
02/04/2019	7.8	11	1.07	AA
14/05/2019	7.8	32	5.48	AA
18/06/2019	7.9	6	0.61	AA
16/07/2019	8.0	5	1.20	AA
20/08/2019	8.0	4	0.77	AA
17/09/2019	8.0	3	0.46	AA
15/10/2019	8.1	4	0.49	AA
19/11/2019	8.0	10	1.59	AA
17/12/2019	8.3	9	0.96	AA
22/01/2020	8.1	12	1.76	AA
18/02/2020	8.0	7	0.57	

