

CALALA WATER TREATMENT PLANT - CURRENT YEAR

LICENCE PERIOD: 27th Feb 2021 - 26 Feb 2022

POINT 1 NOTE: Monitoring Frequency - Monthly

Sample Date	pH	TSS	Aluminium	Sign Off
EPA Limit	6.5 - 8.5	50	N/A	Initial
30/03/2021	7.6	21	1.64	KP
20/04/2021	7.8	3	0.78	KP
25/05/2021	7.9	4	0.84	KP
15/06/2021	7.9	3	0.41	KP
20/07/2021	7.7	2	0.5	KP
17/08/2021	7.6	3	0.47	KP
14/09/2021	8	<2	0.26	KP
26/10/2021	8	9	0.49	KP
2/11/2021	7.7	<2	0.33	KP
13/12/2021	7.7	18	0.92	KP
18/01/2022	7.8	7	0.5	KP
1/02/2022	7.8	9	0.55	KP

