

CALALA WATER TREATMENT PLANT - CURRENT YEAR

LICENCE PERIOD: 27th Feb 2022 - 26 Feb 2023

POINT 1 NOTE: Monitoring Frequency - Monthly

| Sample Date | pH | TSS | Aluminium | Sign Off |
|-------------|-----------|-----|-----------|----------|
| EPA Limit | 6.5 - 8.5 | 50 | N/A | Initial |
| 15.03.2022 | 7.8 | 4 | 0.37 | KP |
| 19.04.2022 | 7.6 | 2 | 0.36 | KP |
| 10.05.2022 | 7.6 | 5 | 0.73 | KP |
| 14.06.2022 | 7.9 | 4 | 0.26 | KP |
| 18.07.2022 | 7.9 | 2 | 0.46 | KP |
| 15.08.2022 | 7.8 | 7 | 0.95 | KP |
| 26.09.2022 | 8 | 2 | 0.39 | KP |
| 18.10.2022 | 7.7 | 17 | 0.93 | KP |
| 14.11.2022 | 7.9 | 15 | 1.12 | KP |
| 19.12.2022 | 7.9 | 7 | 0.69 | KP |
| 04.01.2023 | 7.9 | 7 | 0.66 | KP |
| 14.02.2023 | 7.9 | 11 | 1.22 | KP |

