

# CALALA WATER TREATMENT PLANT - CURRENT YEAR

LICENCE PERIOD: 27th Feb 2023 - 26 Feb 2024

POINT 1 NOTE: Monitoring Frequency - Monthly

Sample Date	pH	TSS	Aluminium	Sign Off
EPA Limit	6.5 - 8.5	50	N/A	Initial
14.02.2023	7.9	11	1.22	KP
14.03.2023	7.9	8	1.41	KP
11.04.2023	7.9	6	1.34	KP
16.05.2023	8	4	0.61	KP
14.06.2023	7.8	5	1.28	KP
18.07.2023	7.7	16	1.8	KP
15.08.2023	7.7	5	0.89	KP
20.09.2023	7.6	8	1.86	KP
17.10.2023	8.2	11	1.56	KP
14.11.2023	8.7	12	2.46	KP
13.12.2023	7.8	6	0.9	KP
05.01.2024	8	16	1.98	KP

