CALALA WATER TREATMENT PLANT - CURRENT YEAR

LICENCE PERIOD: 27th Feb 2024 - 26 Feb 2025

POINT 1 NOTE: Monitoring Frequency - Monthly

Sample Date	pH	TSS	Aluminium	Sign Off
EPA Limit	6.5 - 8.5	50	N/A	Initial
20.02.2024	8.1	16	0.5	KP
19.03.2024	8	4	0.79	KP