

TAMWORTH ERF - CURRENT YEAR

ERF DISCHARGE (LP22)

LICENCE PERIOD: 1st Mar 2022 - 28th Feb 2023

Frequency	N/A	Yearly	N/A	Yearly	Monthly	Monthly	Yearly	Yearly	Yearly	Monthly	Yearly	Yearly	Monthly	Monthly	Monthly	Monthly	Monthly	Yearly	Monthly	Monthly	Yearly	Monthly	Weekly	N/A	Weekly	Monthly	Yearly
DATE SAMPLED	pH	Arsenic	BOD	Cadmium	Calcium	Chloride	Chromium	Copper	Lead	Magnesium	Mercury	Nickel	Nitrate	Nitrite	Ammonia	Total N	Oil and Grease	OC/OP	Total P	Potassium	Selenium	Sodium	Thermo. Coliforms	TSS	TDS	TKN	Zinc
	pH Units	ug/L	mg/L	ug/L	mg/L	mg/L	ug/L	ug/L	ug/L	mg/L	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	mg/L	ug/L	mg/L	mg/L	ug/L	mg/L	CFU/100mL	mg/L	mg/L	mg/L	ug/L
1/03/2022	9.0	NA	4	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.12	1.7	<5	NA	1.52	40	NA	NA	≈16	11	616	NA	NA
8/03/2022	9.1	<0.0001	<2	<0.0001	33	163	<0.01	0.005	<0.001	21	<0.0001	0.002	0.02	0.01	0.83	1.4	<5	<0.01	1.53	37	<0.01	150	≈1	3	580	1.4	0.007
15/03/2022	9.2	NA	7	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.02	1.9	<5	NA	1.64	37	NA	NA	≈1	16	572	NA	NA
22/03/2022	9.3	NA	3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.10	1.5	<5	NA	1.64	36	NA	NA	≈1	13	612	NA	NA
29/03/2022	8.9	NA	7	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.22	1.5	<5	NA	1.17	37	NA	NA	<1	6	584	NA	NA
5/04/2022	9.1	<0.001	4	<0.0001	32	208	<0.01	0.003	<0.001	20	<0.0001	0.002	<0.10	<0.10	<0.10	1.3	<5	<0.010	1.57	36	<0.01	148	<1	5	596	1.3	0.007
12/04/2022	9.0	NA	2	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.12	1.0	<5	NA	1.30	37	NA	NA	<1	4	584	NA	NA
20/04/2022	9.2	NA	2	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.1	1.4	<5	NA	1.56	37	NA	NA	≤1	8	600	NA	NA
28/04/2022	9.4	NA	3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.10	1.4	<5	NA	1.67	36	NA	NA	≈1	10	480	NA	NA
3/05/2022	9.1	NA	4	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.10	1.5	<5	NA	1.65	38	NA	NA	<1	9	480	NA	NA
17/05/2022	8.9	NA	3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.5	1.6	<5	NA	1.51	38	NA	NA	-2	7	508	NA	NA
24/05/2022	9.1	NA	<2	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.1	<5	NA	1.48	37	NA	NA	≈1	8	560	NA	NA
7/06/2022	9.1	NA	3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.1	1.5	<5	NA	1.44	37	NA	NA	<1	9	544	NA	NA
14/06/2022	9.2	<0.001	3	<0.0001	34	169	<0.01	0.005	<0.001	22	<0.0001	0.002	<0.10	<0.10	<0.1	1.7	<5	NA	1.39	37	<0.1	153	<1	11	600	1.7	0.014
21/06/2022	9.3	NA	5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.1	1.5	<5	NA	1.43	34	NA	NA	<1	10	616	NA	NA
28/06/2022	9.2	NA	5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.1	2.7	<5	NA	1.42	36	NA	NA	<1	7	636	NA	NA
5/07/2022	9.1	NA	3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.10	1.9	<5	NA	1.52	37	NA	NA	-1	10	600	NA	NA
12/07/2022	9.1	<0.001	3	<0.0001	34	157	<0.01	0.002	<0.001	20	<0.0001	0.002	0.4	<0.1	0.10	2.0	<5	<0.010	1.51	33	<0.01	136	-1	10	600	1.6	0.012
19/07/2022	9.1	NA	3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.10	1.7	<5	NA	1.50	35	NA	NA	<1	9	620	NA	NA
26/07/2022	9.1	NA	4	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	<0.1	2.0	10	NA	1.45	32	NA	NA	<1	9	608	NA	NA